

(企業ロゴ)	EQUIPMENT DATA SHEET DRY LOAD BANK 200/400V, 50/60Hz – 250kVA	Doc.No:
		Date 2016-04-07
		Rev
		Page 1 / 2

GENERAL			
1.	Manufacturer		TATSUMI RYOKI
2.	Equipment Type		DRY LOAD BANK
3.	Model		L-20
4.	Maximum Ambient Temperature	℃	
5.	Standard		JIS etc.

ELECTRICAL			
6.	<u>Load Ratings (Continuous)</u>		
	Rated Frequency	Hz	50/60
	Rated Voltage	V	200/400
	Rated Apparent Power	kVA	250
	Rated Active Power	kW	200
	Rated Reactive Power	kVAr	—
	Rated Power Factor		1.0
7.	<u>Load Increments</u>		
	Active	kW	5
	Reactive	kVAr	—

FAN & CONTROL CIRCUIT				
		Hz	50	60
8.	Fan Motor Rating	kW		
9.	Fan Voltage Range	V	200	
10.	Control System			
11.	Connection Method			

CIRCUIT BREAKER			
12.	Make		
13.	Type		
14.	Rating	A	
15.	Number of Poles		
16.	Overcurrent Protection Type		
17.	Overcurrent Protection Range	A	
18.	Earth Leakage Protection Type	A	

Approved by:

(企業ロゴ)	EQUIPMENT DATA SHEET DRY LOAD BANK 200/400V, 50/60Hz – 250kVA	Doc.No:
		Date 2016-04-07
		Rev
		Page 2 / 2

ENVIRONMENTAL				
19.	Noise	Hz	50	60
	dBA @ 3m @ 90 ° to Airflow	dBA	60	
20.	Airflow	m ³ /s		
21.	Temperature Rise	°C		

PHYSICAL			
22.	Load Terminal (qty/phase&size)	mm	
23.	Overall Dimensions		
	Width	mm	825
	Length	mm	1090
	Height	mm	825
24.	Weight	kg	170
25.	Lifting Arrangement		

Approved by:
